

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
56099201U262003		Balmoral Elementary School	6/10/17	5:56 AM	DP/KH	BWF-1A	North of Main Office	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	5:57 AM	DP/KH	BWF-1B	North of Main Office	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:03 AM	DP/KH	BWF-3A	SE of Room 9	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	6.83	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:05 AM	DP/KH	BWF-3B	SE of Room 9	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	2.33	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:08 AM	DP/KH	BWF-4A	SW of Room 11	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:09 AM	DP/KH	BWF-4B	SW of Room 11	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:11 AM	DP/KH	BWF-5A	NW of Room 18	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:13 AM	DP/KH	BWF-5B	NW of Room 18	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:14 AM	DP/KH	BWF-6A	SW of Room 19	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:16 AM	DP/KH	BWF-6B	SW of Room 19	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:19 AM	DP/KH	BWF-7A	S of Room 24	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:21 AM	DP/KH	BWF-7B	S of Room 24	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:23 AM	DP/KH	BWF-8A	E of Room 25	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	6.62	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:25 AM	DP/KH	BWF-8B	E of Room 25	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	38.80	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:27 AM	DP/KH	BWF-9A	SE of Room 32	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	2.76	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:28 AM	DP/KH	BWF-9B	SE of Room 32	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:29 AM	DP/KH	BCS-10A	In Room 29	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	26.40	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:30 AM	DP/KH	BCS-10B	In Room 29	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	3.27	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:34 AM	DP/KH	BCS-11A	In Room 30	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	12.70	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:35 AM	DP/KH	BCS-11B	In Room 30	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	2.10	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:35 AM	DP/KH	BS-12A	In Room 30 (Kindergarten Bathroom Sink)	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:36 AM	DP/KH	BS-12B	In Room 30 (Kindergarten Bathroom Sink)	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:38 AM	DP/KH	BCS-13A	In Room 32	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	16.80	2.00	

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
56099201U262003		Balmoral Elementary School	6/10/17	6:39 AM	DP/KH	BCS-13B	In Room 32	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	2.09	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:41 AM	DP/KH	BS-14A	In Room 32 (Kindergarten Bathroom Sink)	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	2.25	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:42 AM	DP/KH	BS-14B	In Room 32 (Kindergarten Bathroom Sink)	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:43 AM	DP/KH	BWF-15A	W of Room 32	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:45 AM	DP/KH	BWF-15B	W of Room 32	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:47 AM	DP/KH	BS-16A	In Room 31	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	2.43	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:48 AM	DP/KH	BS-16B	In Room 31	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:52 AM	DP/KH	BS-17A	W Side in Room 38	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	5.36	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:53 AM	DP/KH	BS-17B	W Side in Room 38	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:53 AM	DP/KH	BS-18A	E Side in Room 38	S - Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	3.03	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:54 AM	DP/KH	BS-18B	E Side in Room 38	S - Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:56 AM	DP/KH	BWF-19A	In Multipurpose Room	DF - Drinking Fountain	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	6:58 AM	DP/KH	BWF-19B	In Multipurpose Room	DF - Drinking Fountain	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	7:01 AM	DP/KH	BKS-20A	S Side in Kitchen	KS - Kitchen Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	7:02 AM	DP/KH	BKS-20B	S Side in Kitchen	KS - Kitchen Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	7:03 AM	DP/KH	BKS-21A	W Side in Kitchen	KS - Kitchen Sink	6/9/2017	7:00pm	First Draw	250	Prairie Analytical	EPA 200.8	2.95	2.00	
56099201U262003		Balmoral Elementary School	6/10/17	7:03 AM	DP/KH	BKS-21B	W Side in Kitchen	KS - Kitchen Sink	6/9/2017	7:00pm	Flush	250	Prairie Analytical	EPA 200.8	U	2.00	

Column Title	Description
ISBE ID	References the Region County District Type Schools (RCDTs) number provided by schools on the Chain of Custody to the lab.
Building ID	A 4-digit numeric code established by the schools to designate the building being sampled. If only one building is present on-campus then it should be designated 0001. A second building, such as an athletic center, would be designated 0002 and so forth for each additional building.
Building Description	A brief description of the building sampled. For example, concession stand.
Sample Date	The sample date should match the Chain of Custody and should follow month/day/year (MM/DD/YYYY).
Sample Time (12 HR Clock)	The sample time should match the Chain of Custody.
Collected By	The name or initials of the person who conducted the sampling.
Sample ID Number	This number is established by the person conducting the testing and should match the Sample Number on the Chain of Custody
Sample Location Description	This description is established by the person conducting the testing and should match Chain of Custody.
Fixture Type	The fixture type should be limited to the drop down menu. If "Other" is selected, a description of the fixture type should be referenced in the Notes of
Date of Last Use	The date should follow month/day/year format (MM/DD/YYYY).
Time of Last Use (12 HR Clock)	The time is used to verify that sampling comported with the mandated stagnation period of 8 to 18 hours.
Sample Type	The sample type should be limited to the drop down menu.
Sample Volume (mL)	First draw and flush samples should be collected in a sterile 250 milliliter (mL) container designated for the collection of potable water.
Laboratory Name	Testing should be conducted only at Illinois EPA-accredited laboratories.
Analytical Method	The analytical method should be limited to the drop down menu.
Concentration (ug/L)	Results are to be reported with three significant digits and units of ppb or microgram per liter (µg/L). For example, 5.12 ppb.
Reporting Limit (ug/L)	A minimum reporting limit of 2.00 ppb must be used.
Notes	Any additional relevant information.
Resources	<ul style="list-style-type: none"> • Lead in Water: http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water • Public Act 99-0922: http://www.ilga.gov/legislation/publicacts/99/PDF/099-0922.pdf • US EPA testing methods: https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P100PHGZ.txt • IEPA Certified Labs: http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index • Sampling Guidance: http://dph.illinois.gov/sites/default/files/publications/sampling-drinking-water-guidance-021617.pdf