

Talala Elementary (ISBE ID: 56009201U262007) - Tested By: PDC Laboratories, Inc. (Method Name: EPA 200.8)

SAMPLE ID NUMBER	SAMPLE LOCATION DESCRIPTION	FIXTURE TYPE	SAMPLE TYPE	CONCENTRATION (ug/l)	ReportingLevel(ug/l)
9094684-01	TE NURSE	Point of Consumption	1ST DRAW	3.36	1.00
9094684-02	TE NURSE 2D		2ND DRAW	ND	1.00
9094684-03	TE TEACHERS	Teacher's Lounge	1ST DRAW	1.03	1.00
9094684-04	TE TEACHERS 2D		2ND DRAW	ND	1.00
9094684-05	TE 11B GIRLS S2	Handsink	1ST DRAW	4.88	1.00
9094684-06	TE 11B GIRLS S2 2D		2ND DRAW	1.49	1.00
9094684-07	TE 11B GIRLS S3	Handsink	1ST DRAW	4.2	1.00
9094684-08	TE 11B GIRLS S3 2D		2ND DRAW	1.21	1.00
9094684-09	TE 11B GIRLS S1	Handsink	1ST DRAW	739	1.11
9094684-10	TE 11B GIRLS S1 2D		2ND DRAW	10.3	1.00
9094684-11	TE 11B BOYS S1	Handsink	1ST DRAW	1.83	1.00
9094684-12	TE 11B BOYS S1 2D		2ND DRAW	ND	1.00
9094684-13	TE 11B BOYS S2	Handsink	1ST DRAW	10.2	1.00
9094684-14	TE 11B BOYS S2 2D		2ND DRAW	ND	1.00
9094684-15	TE 11B BOYS S3	Handsink	1ST DRAW	4.24	1.00
9094684-16	TE 11B BOYS S3 2D		2ND DRAW	ND	1.00
9094684-17	TE RM 7 DF1	Point of Consumption	1ST DRAW	4.8	1.00
9094684-18	TE RM 7 DF1 2D		2ND DRAW	ND	1.00
9094684-19	TE RM 7 DF2	Point of Consumption	1ST DRAW	ND	1.00
9094684-20	TE RM 7 DF2 2D		2ND DRAW	ND	1.00
9094684-21	TE CAFE S1	Point of Consumption	1ST DRAW	ND	1.00
9094684-22	TE CAFE S1 2D		2ND DRAW	ND	1.00
9094684-23	TE CAFE S2	Point of Consumption	1ST DRAW	ND	1.00
9094684-24	TE CAFE S2 2D		2ND DRAW	ND	1.00
9094684-25	TE RM 17 DF1	Point of Consumption	1ST DRAW	11.7	1.00
9094684-26	TE RM 17 DF1 2D		2ND DRAW	2.3	1.00
9094684-27	TE RM 17 DF2	Point of Consumption	1ST DRAW	28.3	1.11
9094684-28	TE RM 17 DF2 2D		2ND DRAW	1.4	1.00
9094684-29	TE RM 17 GIRLS S1	Handsink	1ST DRAW	ND	1.00
9094684-30	TE RM 17 GIRLS S1 2D		2ND DRAW	ND	1.00
9094684-31	TE RM 17 GIRLS S2	Handsink	1ST DRAW	2.71	1.00
9094684-32	TE RM 17 GIRLS S2 2D		2ND DRAW	1.22	1.00
9094684-33	TE RM 17 BOYS S1	Handsink	1ST DRAW	1.06	1.00
9094684-34	TE RM 17 BOYS S1 2D		2ND DRAW	ND	1.00
9094684-35	TE RM 17 BOYS S2	Handsink	1ST DRAW	ND	1.00
9094684-36	TE RM 17 BOYS S2 2D		2ND DRAW	ND	1.00
9094684-37	TE RM 25 BATH	Kdg Bathroom Sink	1ST DRAW	1.82	1.00
9094684-38	TE RM 25 BATH 2D		2ND DRAW	ND	1.00
9094684-39	TE RM 25 SINK	Kdg Sink	1ST DRAW	9.27	1.00
9094684-40	TE RM 25 SINK 2D		2ND DRAW	ND	1.00
9094684-41	TE RM 25 DF	Point of Consumption	1ST DRAW	6.84	1.00
9094684-42	TE RM 25 DF 2D		2ND DRAW	6.82	1.00

9094684-43	TE RM 24 BATH	Kdg Bathroom Sink	1ST DRAW	ND	1.00
9094684-44	TE RM 24 BATH 2D		2ND DRAW	ND	1.00
9094684-45	TE RM 24 SINK	Kdg Sink	1ST DRAW	163	1.00
9094684-46	TE RM 24 SINK 2D		2ND DRAW	10.2	1.00